BASEC
BRITISH APPROVALS SERVICE FOR CABLES

Product Certification Schedule

Schedule No:	017/006/086
Licensee:	PRYSMIAN CABLES & SYSTEMS LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU
Factory:	PRYSMIAN CABLES & SYSTEMS LTD, WREXHAM INDUSTRIAL ESTATE, WREXHAM, WREXHAM, LL13 9PH
Specification:	BS 5467:2016 Incorporating Corrigendum No. 1 Electric cables. Thermosetting insulated, armoured cables of rated voltages of 600/1000 V and 1900/3300 V for fixed installations. Specification
Type of Cable:	Table 4 Single-core 600/1000V cables with copper conductors
HAR Document:	Not applicable
HAR Specification:	Not applicable
Range of Approval:	120sqmm to 1000sqmm nominal cross-sectional area of conductors inclusive. Single-core. Sheath - Type 9. Insulation - GP8.
Origin Thread:	Not applicable
Origin Mark:	PRYSMIAN (W) or BRITCABLE (W)

PERMISSIBLE MARKS

BASEC

YELLOW ACETATE THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 11/08/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 02/08/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

UKAS PRODUCT CERTIFICATION 004