BASEC
BRITISH APPROVALS SERVICE FOR CABLES

Product Certification Schedule

Schedule No:	040/001/362
Licensee:	DONCASTER CABLES, MILLFIELDS INDUSTRIAL ESTATE, ARKSEY LANE, BENTLEY, DONCASTER, SOUTH YORKSHIRE, UNITED KINGDOM, DN5 0SJ
Factory:	DONCASTER CABLES, MILLFIELDS INDUSTRIAL ESTATE, ARKSEY LANE, BENTLEY, DONCASTER, SOUTH YORKSHIRE, UNITED KINGDOM, DN5 0SJ
Specification:	BS 5467:2016 Incorporating Corrigendum No. 1 Electric cables. Thermosetting insulated, armoured cables of rated voltages of 600/1 000 V and 1 900/3 300 V for fixed installations.
Type of Cable:	Table 9 Multicore auxiliary 600/1 000 V cables with copper conductors
Range of Approval:	1.5sqmm to 4sqmm nominal cross-sectional area of conductors inclusive. 7-core to 19-core inclusive. Class 2 conductor. Sheath - Type 9. Insulation - GP8.
Origin Thread:	BLUE/BROWN/GREY/ORANGE
Origin Mark:	DONCASTER CABLES

PERMISSIBLE MARKS

BASEC

YELLOW ACETATE THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 05/02/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 31/07/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

UKAS PRODUCT CERTIFICATION 0004