

Product Certification Schedule

Schedule No: 046/001/056
Licensee: TRATOS CAVI SPA, 52036 PIEVE E STEFANO, VIA STADIO 2, ITALY
Factory: TRATOS CAVI SPA, 52036 PIEVE E STEFANO, VIA STADIO 2, ITALY
Specification: BS 6724:1997 & A3:2008 Electric cables - Thermosetting insulated, armoured cables for voltages of 600/1000V and 1900/3300V having low emission of smoke and corrosive gases when affected by fire
Type of Cable: Table 4 - Single-core 600/1000V cables with circular stranded copper conductor
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: 50sqmm to 400sqmm nominal cross-sectional area of conductors inclusive. Single-core. Sheath - LTS1. Insulation - GP8 .
Origin Thread: Not applicable
Origin Mark: +TRATOS+ or TRATOS

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 06/07/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 05/07/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

