

## Certificate of Product Approval

Licensee:

**Tratos Cavi SpA (Pieve)**

Via Stadio, Pieve, 52036, Italy

Factory:

52036 Pieve S Stefano (Ar), Via Stadio, Italy

Standard:

BS 7870-4.10:2011 and A1:2016

Description:

Medium voltage distribution cables up to 33kV

Details:

Type A: 1, 70-800sqmm stranded circular copper or aluminium class 2 conductors, XLPE (DIX3) insulation, bonded extruded semi-conducting insulation screen, copper wire screen, polythene sheath (DMP5).

Materials:

Insulation XLPE, Sheath NA

Brand Name:

N/A

Origin Mark:

+TRATOS+ or TRATOS

### Permissible Approval Marks:

**BASEC**



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals  
Service for Cables

*Tony Lioveri*

Date: 24/03/2020

Date of original issue: 15/11/2016

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:  
**06/06/2023**



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
2	N/A	Class 2	1	70	800
3	N/A	Class 2	1	70	800
4	N/A	Class 2	1	70	800

Signed for and on behalf of the British Approvals Service for Cables

*Tony Lioveri*

Date: 24/03/2020

Date of original issue: 15/11/2016

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:  
**06/06/2023**