

Product Certification Schedule

Schedule No: 048/001/206
Licensee: TRATOS (UK) LIMITED, RANGLES ROAD, KNOWSLEY, MERSEYSIDE, L34 9HX
Factory: TRATOS (UK) LIMITED, RANGLES ROAD, KNOWSLEY, MERSEYSIDE, L34 9HX
Specification: BS EN 50525-3-41:2011 - Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (Uo/U) - Part 3-41: Cables with special fire performance - Single core non-sheathed cables with halogen-free crosslinked insulation, and low emission of smoke
Type of Cable: Heat resistant cables (90°C)
Clause 4.2 - Cables for fixed wiring - H07Z-K
Table B.2 - Cables with flexible conductor (450/750 V)
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: 1.5sqmm to 6sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 5 conductor. Insulation - EI5.
Origin Thread: BROWN/GREY/ORANGE/YELLOW
Origin Mark: x TRATOS x

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 17/01/2019

Signed for and on behalf of the British Approvals Service for Cables

Date 20/01/2016

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004