

BASEC

BRITISH APPROVALS SERVICE FOR CABLES

Product Certification Schedule

Schedule No: 048/001/218
Licensee: TRATOS (UK) LIMITED, RANGLES ROAD KNOWSLEY, MERSEYSIDE, L34 9HX
Factory: TRATOS (UK) LIMITED, RANGLES ROAD, KNOWSLEY, MERSEYSIDE, L34 9HX
Specification: BS 5467:1997 & A3:2008 - Specification for 600/1000V and 1900/3300V armoured electric cables having thermosetting insulation.
Type of Cable: Tables 6, 8 and 10 - Two-core, three-core and four-core 600/1000V cables with stranded copper conductors
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: 1.5sqmm to 16sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. Sheath - Type 9. Insulation - GP8.
Origin Thread: BROWN/GREY/ORANGE/YELLOW
Origin Mark: x TRATOS x

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 17/01/2019

Signed for and on behalf of the British Approvals Service for Cables

Date 20/01/2015

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004