

Product Certification Schedule

Schedule No: 048/001/222

Licensee: TRATOS (UK) LIMITED, RANGLES ROAD, KNOWSLEY, MERSEYSIDE, L34 9HX

Factory: TRATOS (UK) LIMITED, RANGLES ROAD, KNOWSLEY, MERSEYSIDE, L34 9HX

Specification: BS 6004:2012 Electric Cables - PVC insulated and PVC sheathed cables for voltages up to and including 300/500V, for electric power and lighting

Type of Cable: Table 3 PVC insulated, PVC sheathed cable, 300/500 V, single core 6181Y, flat twin 6192Y and flat 3-core 6193Y

Range of Approval: 1sqmm to 2.5sqmm nominal cross-sectional area of conductors inclusive. Single-core to flat 3-core inclusive. Class 1 conductor. 4sqmm to 35sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 2 conductor. 4sqmm to 16sqmm nominal cross-sectional area of conductors inclusive. Flat twin to flat 3-core inclusive. Class 2 conductor. Sheath - Type 6. Insulation - T11.

Origin Thread: BROWN/GREY/ORANGE/YELLOW

Origin Mark: x TRATOS x

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 17/01/2022

Signed for and on behalf of the British Approvals Service for Cables

Tracie Hunter.

Date 10/01/2019

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



0004