

Product Certification Schedule

Schedule No: 048/001/228

Licensee: TRATOS (UK) LIMITED, RANGLES ROAD, KNOWSLEY, MERSEYSIDE, L34 9HX

Factory: TRATOS (UK) LIMITED, RANGLES ROAD, KNOWSLEY, MERSEYSIDE, L34 9HX

Specification: BS EN 50525-3-41:2011 Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (Uo/U) - Part 3-41: Cables with special fire performance - Single core non-sheathed cables with halogen-free crosslinked insulation, and low emission of smoke

Type of Cable: Clause 4.2 Table B.2 Heat resistant cables (90oC) Clause 4.2 - Cables for fixed wiring - H07Z-K Table B.2 - Cables with flexible conductor (450/750 V)

Range of Approval: 1.5sqmm to 6sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 5 conductor. Insulation - EI5.

Origin Thread: BROWN/GREY/ORANGE/YELLOW

Origin Mark: x TRATOS x

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 17/01/2022

Signed for and on behalf of the British Approvals Service for Cables

Tracie Hunter.

Date 10/01/2019

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

