

Product Certification Schedule

Schedule No: 066/001/174

Licensee: KEYSTONE ELECTRIC WIRE & CABLE CO., LTD., #110 D.D. 83 KWAN TI NORTH VILLAGE, P.O. BOX 376, FANLING POST OFFICE, FANLING, N.T., HONG KONG

Factory: KEYSTONE ELECTRIC WIRE & CABLE CO., LTD., #110 D.D. 83 KWAN TI NORTH VILLAGE, FANLING, N.T., HONG KONG

Specification: BS 6346:1997 Incorporating Amendments Nos. 1 & 2 Electric cables - PVC insulated, armoured cables for voltages of 600/1000V and 1900/3300V

Type of Cable: Tables 7, 9 and 11 - Two-core, three-core and four-core 600/1000V cables with stranded copper conductors

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.5sqmm to 400sqmm nominal cross-sectional area of conductors inclusive. Two-core, three-core and four-core inclusive. Sheath - TM1. Insulation - TI1.
Note: The above cables conform to BS6346 and, by reference, conform to the appropriate requirements of BS EN 60228.

Origin Thread: Green White Yellow

Origin Mark: - KEYSTONE -

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 12/07/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 28/06/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

