

## Product Certification Schedule

Schedule No: 075/001/181

Licensee: DONGGUAN KEYSTONE ELECTRIC WIRE & CABLE CO LTD, YE SHA MANAGEMENT DISTRICT, SHATIAN, DONGGUAN CITY, GUANGDONG 523998, PEOPLES REPUBLIC OF CHINA

Factory: DONGGUAN KEYSTONE ELECTRIC WIRE & CABLE CO LTD, YE SHA MANAGEMENT DISTRICT, SHATIAN, DONGGUAN CITY, GUANGDONG 523998, PEOPLES REPUBLIC OF CHINA

Specification: BS 7889:1997 Incorporating Amendments Nos 1, 2 & 3 and Corrigendum 1 - Electric cables - Thermosetting insulated, unarmoured cables for a voltage of 600/1000 V. Core colour requirements specified in clause 7.1 are modified to permit the use of alternative colours to meet regulatory or statutory requirements.

Type of Cable: Table 4 - Single-core 600/1000 V cables as per Table 4 except with circular sectoral stranded aluminium conductor comply with BS 6360:1991.

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 600sqmm to 1200sqmm nominal cross-sectional area of conductors inclusive. Single-core. Sheath - Type 9. Insulation GP8.  
The core shall be identified by the colours red or black either throughout the insulation or on its external surface.  
Note: The above cables conform to BS 7889 and, by reference, conform to the appropriate requirements of BS EN 60228.

Origin Thread: Not applicable

Origin Mark: <KEYSTONE>

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 01/09/2019

Signed for and on behalf of the British Approvals Service for Cables

Date 18/08/2016

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

