

# BASEC

BRITISH APPROVALS SERVICE FOR CABLES

## Product Certification Schedule

Schedule No: 075/001/184

Licensee: DONGGUAN KEYSTONE ELECTRIC WIRE & CABLE CO LTD, YE SHA MANAGEMENT DISTRICT, SHATIAN, DONGGUAN CITY, GUANGDONG 523998, PEOPLES REPUBLIC OF CHINA

Factory: DONGGUAN KEYSTONE ELECTRIC WIRE & CABLE CO LTD, YE SHA MANAGEMENT DISTRICT, SHATIAN, DONGGUAN CITY, GUANGDONG 523998, PEOPLES REPUBLIC OF CHINA

Specification: BS 6500:2000 Incorporating Amendment Nos. 1, 2 & 3 and Corrigendum No. 1 & 2 - Electric Cables - Flexible cords rated up to 300/500 V, for use with appliances and equipment intended for domestic, office and similar environments

Type of Cable: Table 27 - Ordinary duty PVC insulated and sheathed flexible cord, parallel twin, circular twin, 3-core, 4-core and 5-core, 300/500V

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 0.75sqmm to 2.5sqmm nominal cross-sectional area of conductors inclusive. Twin-core to 5-core inclusive. Sheath - TM2. Insulation - TI2.  
Note: The above cables conform to BS 6500 and, by reference, conform to the appropriate requirements of BS EN 60228.

Origin Thread: Not applicable

Origin Mark: <KEYSTONE>

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 01/09/2019

Signed for and on behalf of the British Approvals Service for Cables

Date 18/08/2016

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

