

Product Certification Schedule

Schedule No: 075/001/189

Licensee: DONGGUAN KEYSTONE ELECTRIC WIRE & CABLE CO LTD, YE SHA MANAGEMENT DISTRICT, SHATIAN, DONGGUAN CITY, GUANGDONG 523998, PEOPLES REPUBLIC OF CHINA

Factory: DONGGUAN KEYSTONE ELECTRIC WIRE & CABLE CO LTD, YE SHA MANAGEMENT DISTRICT, SHATIAN, DONGGUAN CITY, GUANGDONG 523998, PEOPLES REPUBLIC OF CHINA

Specification: BS 7889:1997 Incorporating Amendment Nos. 1, 2 & 3 and Corrigendum No.1 - 600/1000V single-core unarmoured electric cables having thermosetting insulation

Type of Cable: Table 4 - Single-core 600/1000V cables as per Table 4 except with circular sectoral stranded aluminium conductor complying with BS 6360:1991.

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 600sqmm to 1200sqmm nominal cross-sectional area of conductors inclusive. Single-core. 960sqmm nominal cross-sectional area of conductor which shall comprise of four sector shaped sections laid up together. Sheath - Type 9. Insulation - GP8.
Note: The above cables conform to BS 7889 and, by reference, conform to the appropriate requirements of BS EN 60228.

Origin Thread: Not applicable

Origin Mark: <KEYSTONE>

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 01/09/2019

Signed for and on behalf of the British Approvals Service for Cables

Date 18/08/2016

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004