

Product Certification Schedule

Schedule No: 075/001/201

Licensee: DONGGUAN KEYSTONE ELECTRIC WIRE & CABLE CO LTD, YE SHA MANAGEMENT DISTRICT, SHATIAN, DONGGUAN CITY, GUANGDONG 523998, PEOPLES REPUBLIC OF CHINA,

Factory: DONGGUAN KEYSTONE ELECTRIC WIRE & CABLE CO LTD, YE SHA MANAGEMENT DISTRICT, SHATIAN, DONGGUAN CITY, GUANGDONG 523998, PEOPLES REPUBLIC OF CHINA

Specification: BS 6004:2012 - Electric Cables - PVC insulated and PVC sheathed cables for voltages up to and including 300/500V, for electric power and lighting

Type of Cable: Table 4 - PVC insulated, PVC sheathed cable with circuit protective conductor (CPC), 300/500 V, single core 6241Y, flat twin 6242Y and flat 3-core 6243Y

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1sqmm to 1.5sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 1 conductor. 1sqmm to 2.5sqmm nominal cross-sectional area of conductors inclusive. Flat twin. Class 1 conductor. 4sqmm to 16sqmm nominal cross-sectional area of conductors inclusive. Flat twin. Class 2 conductor. Sheath - Type 6. Insulation - T11.
Note: The above cables conform to BS 6004 and, by reference, conform to the appropriate requirements of BS EN 60228.

Origin Thread: Not applicable

Origin Mark: <KEYSTONE>

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 01/09/2019

Signed for and on behalf of the British Approvals Service for Cables

Date 18/08/2016

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

