



BRITISH APPROVALS SERVICE FOR CABLES

Product Certification Schedule

Schedule No: 075/001/202

Licensee: DONGGUAN KEYSTONE ELECTRIC WIRE & CABLE CO LTD, YE SHA MANAGEMENT DISTRICT, SHATIAN, DONGGUAN CITY, GUANGDONG 523998, PEOPLES REPUBLIC OF CHINA,

Factory: DONGGUAN KEYSTONE ELECTRIC WIRE & CABLE CO LTD, YE SHA MANAGEMENT DISTRICT, SHATIAN, DONGGUAN CITY, GUANGDONG 523998, PEOPLES REPUBLIC OF CHINA

Specification: BS 6004:2012 - Electric Cables - PVC insulated and PVC sheathed cables for voltages up to and including 300/500V, for electric power and lighting

Type of Cable: Table 5 - PVC insulated, PVC sheathed cable with or without circuit protective conductor (CPC), 300/500 V, single core 6241Y and flat twin (6192Y and 6242Y) (alternative conductor versions).

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.5sqmm nominal cross-sectional area of conductor. Single-core. Class 2 conductor, with CPC. 1.5sqmm to 2.5sqmm nominal cross-sectional area of conductors inclusive. Flat twin. Class 2 conductor, with and without CPC. Sheath - Type 6. Insulation - T11.
Note: The above cables conform to BS 6004 and, by reference, conform to the appropriate requirements of BS EN 60228.

Origin Thread: Not applicable

Origin Mark: <KEYSTONE>



PERMISSIBLE MARKS

BASEC

Please refer to the BASEC Product Certification Requirements

**YELLOW
ACETATE
THREAD**

Expiry Date: 01/09/2019

Signed for and on behalf of the British Approvals Service for Cables

Date 18/08/2016

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

