

Product Certification Schedule

Schedule No: 075/001/208

Licensee: DONGGUAN KEYSTONE ELECTRIC WIRE & CABLE CO LTD, YE SHA MANAGEMENT DISTRICT, SHATIAN, DONGGUAN CITY, GUANGDONG 523998, PEOPLES REPUBLIC OF CHINA,

Factory: DONGGUAN KEYSTONE ELECTRIC WIRE & CABLE CO LTD, YE SHA MANAGEMENT DISTRICT, SHATIAN, DONGGUAN CITY, GUANGDONG 523998, PEOPLES REPUBLIC OF CHINA

Specification: BS 7889:2012 - Electric cables - Thermosetting insulated, unarmoured cables with a voltage of 600/1000 V, for fixed installations

Type of Cable: Tables 3, 4 & 5 - Two-core, three-core and four-core 600/1000 V cables with stranded copper conductors

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.5sqmm to 120sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. Class 2 circular conductor. 25sqmm to 120sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. Class 2 shaped conductor. Sheath - Type 9. Insulation - GP8. Any core colour sequence meeting regulatory requirements. Note: The above cables conform to BS 7889 and, by reference, conform to the appropriate requirements of BS EN 60228.

Origin Thread: Not applicable

Origin Mark: <KEYSTONE>

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 01/09/2019

Signed for and on behalf of the British Approvals Service for Cables

Date

23/8/2016

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004