

## Product Certification Schedule

Schedule No: 075/001/209

Licensee: DONGGUAN KEYSTONE ELECTRIC WIRE & CABLE CO LTD, YE SHA MANAGEMENT DISTRICT, SHATIAN, DONGGUAN CITY, GUANGDONG 523998, PEOPLES REPUBLIC OF CHINA,

Factory: DONGGUAN KEYSTONE ELECTRIC WIRE & CABLE CO LTD, YE SHA MANAGEMENT DISTRICT, SHATIAN, DONGGUAN CITY, GUANGDONG 523998, PEOPLES REPUBLIC OF CHINA

Specification: BS 7889:2012 - Electric cables - Thermosetting insulated, unarmoured cables with a voltage of 600/1000 V, for fixed installations

Type of Cable: Table 2 - Single-core 600/1000V cables with circular stranded copper conductor

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.5sqmm to 1000sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 2 conductor. Sheath - Type 9. Insulation - GP8. Any core colour sequence meeting regulatory requirements.  
Note: The above cables conform to BS 7889 and, by reference, conform to the appropriate requirements of BS EN 60228.


Origin Thread: Not applicable

Origin Mark: <KEYSTONE>

	<b>PERMISSIBLE MARKS</b>	
	<b>BASEC</b>	<b>YELLOW ACETATE THREAD</b>
Please refer to the BASEC Product Certification Requirements		

Expiry Date: 01/09/2019

Signed for and on behalf of the British Approvals Service for Cables



Date

23/8/2016

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

