



BRITISH APPROVALS SERVICE FOR CABLES

## Product Certification Schedule

Schedule No: 075/001/218

Licensee: DONGGUAN KEYSTONE ELECTRIC WIRE & CABLE CO LTD, YE SHA MANAGEMENT DISTRICT, SHATIAN, DONGGUAN CITY, GUANGDONG 523998, PEOPLES REPUBLIC OF CHINA,

Factory: DONGGUAN KEYSTONE ELECTRIC WIRE & CABLE CO LTD, YE SHA MANAGEMENT DISTRICT, SHATIAN, DONGGUAN CITY, GUANGDONG 523998, PEOPLES REPUBLIC OF CHINA

Specification: BS EN 50525-3-41:2011 - Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (Uo/U) - Part 3-41: Cables with special fire performance - Single core non-sheathed cables with halogen-free crosslinked insulation, and low emission of smoke

Type of Cable: Heat resistant cables (90°C)  
 Clause 4.4 - Cables for internal wiring - H05Z-K  
 Table B.4 - Cables with flexible conductor (300/500 V)

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 0.5sqmm to 1sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 5 conductor. Insulation - EI5.  
 Note: The above cables conform to BS EN 50525-3-41 and, by reference, conform to the appropriate requirements of: BS EN 60228, BS EN 60332-1-2, BS EN 61034-2, BS EN 60754-1, BS EN 60754-2 and BS EN 60684-2 specifications.

Origin Thread: Not applicable

Origin Mark: <KEYSTONE>



**PERMISSIBLE MARKS**

**BASEC**

YELLOW ACETATE THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 01/09/2019

Signed for and on behalf of the British Approvals Service for Cables

Date 18/08/2016

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

