

Product Certification Schedule

Schedule No: 081/001/175

Licensee: NEXANS TURKIYE ENDUSTRI VE TICARET A.S., BOZBURUN MAHALLESİ, AHMET NURI ERIKOGLU CADDESİ NO.2, DENİZLİ, TURKEY

Factory: NEXANS TURKIYE ENDUSTRI VE TICARET A.S., BOZBURUN MAHALLESİ, AHMET NURI ERIKOGLU CADDESİ NO.2, DENİZLİ, TURKEY

Specification: BS 7889:2012 Electric cables - Thermosetting insulated, non-armoured cables with a voltage of 600/1000 V, for fixed installations

Type of Cable: Table 2 Single-core 600/1000V cables with circular stranded copper conductor

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 50sqmm to 1000sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 2 conductor. Sheath - Type 9. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: NEXANS i or NEXANS i) (

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 27/10/2019

Signed for and on behalf of the British Approvals Service for Cables

Date 17/10/2016

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004