

## Certificate of Product Approval

Licensee:

**Nexans Turkiye Endustri ve Ticaret A.S. (Denizli)**

Bozburun Mahallesi

Ahmet Nuri Erikoglu Caddesi No.2, Denizli, Turkey

Factory:

Bozburun Mahallesi

Ahmet Nuri Erikoglu Caddesi No.2, Denizli, Turkey

Standard:

BS 7846:2015

Description:

Armoured fire resistant power cables

Details:

Resistance to Fire Category F120. Tested bend radius 8D.

Materials:

Insulation GP 8, Sheath LTS 1

Brand Name:

N/A

Origin Mark:

NEXANS i or NEXANS i )(

### Permissible Approval Marks:

**BASEC**



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals  
Service for Cables

*Tracie Hunter*

Date: 07/08/2019

Date of original issue: 15/06/2018

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:  
**26/10/2022**



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
4	N/A	Class 2	2	4	400
5	N/A	Class 2	3	4	400
6	N/A	Class 2	4	4	400

Signed for and on behalf of the British Approvals Service for Cables

*Tracie Hunter* Date: 07/08/2019

Date of original issue: 15/06/2018

Check BASEC website to verify validity.

Page 2 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300  
Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:  
**26/10/2022**