

## Product Certification Schedule

Schedule No: 091/002/050

Licensee: GRUPO GENERAL CABLE SISTEMAS, S.L.U., CALLE CASANOVA 150, 08036 BARCELONA, SPAIN

Factory: GRUPO GENERAL CABLE SISTEMAS, S.L.U., CARRETERA DE RIBAS, KM 13, 250. 08110 MONTCADA 1 REIXAC, BARCELONA, SPAIN

Specification: BS 7846:2015 Electric Cables - Thermosetting insulated, armoured, fire-resistant cables of rated voltage 600/1 000 V for fixed installations, having low emission of smoke and corrosive gases when affected by fire - Specification.

Type of Cable: Tables 4, 5 and 6  
Two core, three core and four core 600/1000V cables with copper conductors

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.5sqmm to 400sqmm nominal cross-sectional area of conductors inclusive.  
Two core to four core inclusive.  
Resistance to Fire - Category F2.  
Sheath - LTS1. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: General Cable 3

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 22/07/2019

Signed for and on behalf of the British Approvals Service for Cables

Date 31/01/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004