

Product Certification Schedule

Schedule No: 091/002/051
Licensee: GRUPO GENERAL CABLE SISTEMAS, S.L.U., CARRETERA DE RIBAS, KM 13, 250. 08110 MONTCADA 1 REIXAC, BARCELONA, SPAIN
Factory: GRUPO GENERAL CABLE SISTEMAS, S.L.U., CARRETERA DE RIBAS, KM 13, 250. 08110 MONTCADA 1 REIXAC, BARCELONA, SPAIN
Specification: BS 5467:2016 Incorporating Corrigendum No. 1 Electric cables. Thermosetting insulated, armoured cables of rated voltages of 600/1 000 V and 1 900/3 300 V for fixed installations. Specification
Type of Cable: Table 4 Single-core 600/1000V cables with circular copper conductor
Range of Approval: 50sqmm to 300sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 2 conductor. Sheath - Type 9 . Insulation - GP8
Origin Thread: Not applicable
Origin Mark: General Cable 3

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 22/07/2019

Signed for and on behalf of the British Approvals Service for Cables

Date 09/11/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



0004