

Product Certification Schedule

Schedule No:

091/003/036

Licensee:

GRUPO GENERAL CABLE SISTEMAS, S.L.U., CALLE CASANOVA 150,

08036 BARCELONA, SPAIN

Factory:

GRUPO GENERAL CABLE SISTEMAS, S.L.U., CARRETERA RUSINOL, 63.,

08560 MANLLEU, BARCELONA, SPAIN

Specification:

BS EN 50525-3-41:2011 Electric cables - Low voltage energy cables of rated

voltages up to and including 450/750 V (Uo/U) - Part 3-41: Cables with special

fire performance - Single core non-sheathed cables with halogen-free

crosslinked insulation, and low emission of smoke

Type of Cable:

Heat resistant cables (90°C)

Clause 4.1 - Cables for fixed wiring - H07Z-U and H07Z-R

Table B.1 - Cables with rigid conductor (450/750 V)

HAR Document:

Not applicable

HAR Specification:

Not applicable

Range of Approval:

1.5sqmm to 10sqmm nominal cross-sectional area of conductors inclusive.

Single-core. Class 1 conductor. 1.5sqmm to 400sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 2 conductor. Insulation - El5.

Origin Thread:

Not applicable

Origin Mark:

General Cable 4



PERMISSIBLE MARKS

BASEC

YELLOW ACETATE THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 22/07/2019

Signed for and on behalf of the British Approvals Service for Cables

Date

21/07/2016

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



