BASEC
BRITISH APPROVALS SERVICE FOR CABLES

Product Certification Schedule

Schedule No:	098/003/028
Licensee:	ABERDARE CABLES (PTY) LTD, 181A BARBARA ROAD, ELANDSFONTEIN, GERMISTON, JOHANNESBURG, REPUBLIC OF SOUTH AFRICA
Factory:	ABERDARE CABLES (PTY) LTD, STANDFORD ROAD, NEAVE TOWNSHIP, PORT ELIZABETH, REPUBLIC OF SOUTH AFRICA
Specification:	BS 5467:1997 and A3:2008 Specification for 600/1000V and 1900/3300V armoured electric cables having thermosetting insulation.
Type of Cable:	Tables 6, 8 and 10 - Two-core, three-core and four-core 600/1000V cables with stranded copper conductors
HAR Document:	Not applicable
HAR Specification:	Not applicable
Range of Approval:	25sqmm to 400sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. Sheath - Type 9. Insulation - GP8. SUBJECT TO SPECIAL CONDITIONS - REFER TO BASEC FOR DETAILS
Origin Thread:	Not applicable
Origin Mark:	ABERDARE CABLES STD RD

PERMISSIBLE MARKS

BASEC

YELLOW ACETATE THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 29/10/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 19/10/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

UKAS PRODUCT CERTIFICATION 004