

Product Certification Schedule

Schedule No: 123/001/053
Licensee: HELLENIC CABLES SA, 69TH KM OLD NAT. ROAD, ATHENS-THIVA, THIVA 32200, VIOTIA, GREECE
Factory: HELLENIC CABLES SA, 69TH KM OLD NAT. ROAD, ATHENS-THIVA, THIVA 32200, VIOTIA, GREECE
Specification: BS 6724:2016 Incorporating Corrigenda Nos. 1 and 2 Electric cables - Thermosetting insulated, armoured cables for voltages of 600/1000V and 1900/3300V having low emission of smoke and corrosive gases when affected by fire
Type of Cable: Table 4
Single-core 600/1000V cables with copper conductor
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: 50sqmm to 1000sqmm nominal cross-sectional area of conductors inclusive. Single-core. Sheath - LTS1. Insulation - GP8.
Origin Thread: Not applicable
Origin Mark: CABLEL 0317

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 05/06/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 10/08/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004