

Product Certification Schedule

Schedule No: 134/001/045

Licensee: DRAKA KABELY S.R.O, TREBICKSKA 777/99, 594 01 VELKE MEZIRICI, CZECH REPUBLIC

Factory: DRAKA KABELY S.R.O, TREBICKSKA 777/99, 594 01 VELKE MEZIRICI, CZECH REPUBLIC

Specification: BS EN 50525-2-31:2011 Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (Uo/U) - Part 2-31: Cables for general applications - Single core non-sheathed cables with thermoplastic PVC insulation

Type of Cable: Clause 4.1 Table B.1 Clause 4.1 - Cables for fixed wiring - H07V-U and H07V-R Table B.1 - Cables with rigid conductor (450/750 V)

Range of Approval: 1.5sqmm to 10sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 1 conductor. 1.5sqmm to 16sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 2 conductor. Insulation - T11.

Origin Thread: Not applicable

Origin Mark: DRAKA 07 or -DRAKA-

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 03/09/2021

Signed for and on behalf of the British Approvals Service for Cables

Date 31/08/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



0004