

## Product Certification Schedule

Schedule No: 137/001/063

Licensee: DEMES KABLO SAN. VE TIC LTD. STI, ISTIKLAL MAH. FEVZI CAKMAK CAD. NO:19, ESENYURT/ISTANBUL, TURKEY, 34522

Factory: DEMES KABLO SAN. VE TIC LTD. STI, ISTIKLAL MAH. FEVZI CAKMAK CAD. NO:19, ESENYURT/ISTANBUL, TURKEY, 34522

Specification: BS 7846:2015 Electric Cables - Thermosetting insulated, armoured, fire-resistant cables of rated voltage 600/1 000 V for fixed insulations, having low emission of smoke and corrosive gases when affected by fire - Specification.

Type of Cable: Tables 4, 5, 6, 7 and 8 Two core, three core, four core, five core and multicore auxiliary 600/1000V cables with copper conductors

Range of Approval: 1.5sqmm to 35sqmm nominal cross-sectional area of conductors inclusive. Two core to five core inclusive. 1.5sqmm to 4sqmm nominal cross-sectional area of conductors inclusive. 7-core to 37-core inclusive. Resistance to fire Category F2. Sheath - LTS1. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: DEMES KABLO or HELGIN KABLO or D.K.or DEMES CABLE

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 22/10/2021

Signed for and on behalf of the British Approvals Service for Cables

Date 18/10/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



0004