

## Product Certification Schedule

Schedule No: 137/001/066

Licensee: DEMES KABLO SAN. VE TIC LTDI. STI, ISTIKLAL MAH. FEVZI CAKMAK CAD. NO:19, ESENYURT/ISTANBUL, TURKEY, 34522

Factory: DEMES KABLO SAN. VE TIC LTDI. STI, ISTIKLAL MAH. FEVZI CAKMAK CAD. NO:19, ESENYURT/ISTANBUL, TURKEY, 34522

Specification: BS 5467:2016 Incorporating Corrigendum No. 1 Electric cables - Thermosetting insulated, armoured cables of rated voltages of 600/1000V and 1900/3300V for fixed installations - Specification

Type of Cable: Tables 5, 6, 7 & 8 Two-core, three-core, four-core and five-core 600/1000V cables with copper conductors

Range of Approval: 1.5sqmm to 240sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. 1.5sqmm to 70sqmm nominal cross-sectional area of conductors inclusive. Five-core. Sheath - Type 9. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: DEMES KABLO or HELGIN KABLO or D.K. or DEMES CABLE

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 22/10/2021

Signed for and on behalf of the British Approvals Service for Cables

Date 18/10/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



0004