

## Product Certification Schedule

Schedule No:	152/001/038
Licensee:	VENTCROFT LIMITED, FARADAY ROAD, ASTMOOR INDUSTRIAL ESTATE, RUNCORN, CHESHIRE, WA7 1PE
Factory:	VENTCROFT LIMITED, FARADAY ROAD, ASTMOOR INDUSTRIAL ESTATE, RUNCORN, CHESHIRE, WA7 1PE
Specification:	BS 7629-1:2015 Electric Cables - Specification for 300/500 V fire resistant, screened, fixed installation cables having low emission of smoke and corrosive gases when affected by fire. Part 1: Multicore cables
Type of Cable:	Table 2 Dimensions of 2-core, 3-core and 4-core cables
HAR Document:	Not applicable
HAR Specification:	Not applicable
Range of Approval:	1.0sqmm nominal cross-sectional area of conductor. 2-core. 1.5sqmm to 4.0sqmm nominal cross-sectional area of conductors inclusive. 2-core to 4-core inclusive. STANDARD 60. Additionally tested to BS 6387 Categories C, W & Z. Sheath - LTS3. Insulation - EI2.
Origin Thread:	Not applicable
Origin Mark:	NOBURN PLATINUM or JAYFLAME or FIRETRAX GOLD or ZEROBURN

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 07/12/2019

Signed for and on behalf of the British Approvals Service for Cables

Date 21/12/2016

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004