

Certificate of Product Approval

Licensee:

Ventcroft Ltd

Faraday Road

Astmoor Industrial Estate, Runcorn, WA7 1PE, Cheshire, United Kingdom

Factory:

Faraday Road

Astmoor Industrial Estate, Runcorn, WA7 1PE, Cheshire, United Kingdom

Standard:

BS 7629-1:2015

Description:

Fire resistant screened cables

Details:

STANDARD 60. Additionally tested to BS 6387 Categories C, W & Z.

Materials:

Insulation EI 2, Sheath LTS 3

Brand Name:

FireTrax Gold

Origin Mark:

NOBURN PLATINUM, JAYFLAME, FIRETRAX GOLD, ZEROBURN

Permissible Approval Marks:

BASEC

BASEC name



BASEC roundel

Signed for and on behalf of BASEC Group Ltd



Date: 20/11/2025

Date of original issue: 18/06/2024

Check BASEC website to verify validity.

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 6 (11-11-2024) Page 1 of 2



Expiry date:
09/12/2028

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
2	N/A	N/A	2	1	1
2	N/A	N/A	2	1.5	4
2	N/A	N/A	3	1.5	4
2	N/A	N/A	4	1.5	4

Signed for and on behalf of BASEC Group Ltd

Date: 20/11/2025



Date of original issue: 18/06/2024

Check BASEC website to verify validity.

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No.13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 6 (11-11-2024) Page 2 of 2

Expiry date:
09/12/2028