



Certificate No: 153/001/042

Issue No: 3

Certificate of Product Approval

Licensee:

Dätwyler IT Infra AG

Gotthardstrasse 31, Altdorf, CH-6460, Switzerland

Factory: Gotthardstrasse 31, Altdorf, Switzerland

> Standard: BS 7629-1:2015

Description: Fire resistant screened cables

Details: ENHANCED 120. Additionally tested to BS 6387 Categories C, W & Z.

> Materials: Insulation El 5, Sheath LTS 3

> > Brand Name: N/A

Origin Mark: DATWYLER

Permissible Approval Marks:





BASEC name

BASEC roundel





Service for Cables

Signed for and on behalf of the British Approvals

Date of original issue: 12/03/2008 Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES, Registered in England No. 1150237, Tel: +44(0)1908267300 Email: mail@basec.org.uk, Web: www.basec.org.uk

Expiry date: 02/12/2023





Certificate No: 153/001/042
Issue No: 3

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
2			2	1.5	2.5
2			3	1.5	2.5
2			4	1.5	2.5

Signed for and on behalf of the British Approvals Service for Cables

John Lioveri Date: 07/09/202

Date of original issue: 12/03/2008 Check BASEC website to verify validity.

Page 2 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES, Registered in England No. 1150237, Tel: +44(0)1908267300 Email: mail@basec.org.uk, Web: www.basec.org.uk

