

## Product Certification Schedule

Schedule No: 153/001/043

Licensee: DATWYLER CABLING SOLUTIONS AG, GOTTHARDSTRASSE 31, CH-6460  
ALTDORF, SWITZERLAND

Factory: DATWYLER CABLING SOLUTIONS AG, GOTTHARDSTRASSE 31, CH-6460  
ALTDORF, SWITZERLAND

Specification: BS 7629-1:2015 Electric Cables - Specification for 300/500 V fire resistant,  
screened, fixed installation cables having low emission of smoke and corrosive  
gases when affected by fire. Part 1: Multicore cables

Type of Cable: Table 2 Dimensions of 2-core, 3-core and 4-core cables

Range of Approval: 1.0sqmm nominal cross-sectional area of conductor. 2-core.  
1.5sqmm to 2.5sqmm nominal cross-sectional area of conductors inclusive.  
2-core to 4-core inclusive.  
STANDARD 60.  
Additionally tested to BS 6387 Categories C, W & Z.  
Sheath - LTS3. Insulation - EI5.

Subject to special conditions - refer to BASEC for details.

Origin Thread: Not applicable

Origin Mark: DATWYLER (;) DATWYLER DFS EN (;) DATWYLER DFS ST

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 02/12/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 08/08/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



0004