

Product Certification Schedule

Schedule No: 156/001/023

Licensee: PARAMOUNT COMMUNICATIONS LIMITED, PARAMOUNT HOUSE, C-125, NARAINA INDUSTRIAL AREA, PHASE 1, NEW DELHI - 110028, INDIA

Factory: PARAMOUNT COMMUNICATIONS LIMITED, PLOT NO. SP-30A SP-30B & E-31, RIICO INDUSTRIAL AREA, KHUSHKHERA (NEAR BHIWADI), VILLAGE & P.O: BUDI BAWAL (KAROLI), DISTRICT: ALWAR, RAJASTHAN, PIN: 301707, INDIA

Specification: BS 7846:2015 Electric Cables - Thermosetting insulated, armoured, fire-resistant cables of rated voltage 600/1000 V for fixed insulations, having low emission of smoke and corrosive gases when affected by fire - Specification.

Type of Cable: Tables 4, 5 and 6
Two core, three core and four core 600/1000V cables with copper conductors

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 50sqmm to 400sqmm nominal cross-sectional area of conductors inclusive.
Two core to four core inclusive.
Resistance to fire - Category F120.
Sheath - LTS1. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: PARAMOUNT P-1

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 14/05/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 09/05/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

