

## Certificate of Product Approval

Licensee:

**Paramount Communications Ltd**

C-125, Naraina Industrial Area,  
Phase-1, New Delhi, 110028, India

Factory:

Plot No. SP-30A SP-30B & E-31, RIICO Ind. Area, Khushkhera (near Bhiwadi)  
Village & P.O: Budi Bawal (Karoli), Rajasthan, India

Standard:

BS 7846:2015

Description:

Armoured fire resistant power cables

Details:

Resistance to fire - Category F120.

Materials:

Insulation GP 8, Sheath LTS 1

Brand Name:

N/A

Origin Mark:

PARAMOUNT P-1

### Permissible Approval Marks:

**BASEC**



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals  
Service for Cables

*Tony Lioveri*

Date: 04/09/2020

Date of original issue: 09/12/2011

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:  
**14/05/2023**

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
4	N/A	Class 2	2	50	400
5	N/A	Class 2	3	50	400
6	N/A	Class 2	4	50	400

Signed for and on behalf of the British Approvals  
Service for Cables

*Tony Lioveri*

Date: 04/09/2020

Date of original issue: 09/12/2011

Check BASEC website to verify validity.

Page 2 of 2



Expiry date:  
**14/05/2023**