

Product Certification Schedule

Schedule No: 156/001/024

Licensee: PARAMOUNT COMMUNICATIONS LIMITED, PARAMOUNT HOUSE, C-125, NARAINA INDUSTRIAL AREA, PHASE 1, NEW DELHI - 110028, INDIA

Factory: PARAMOUNT COMMUNICATIONS LIMITED, PLOT NO. SP-30A, SP-30B & E-31, RIICO INDUSTRIAL AREA, KHUSHKHERA (NEAR BHIWADI), VILLAGE & P.O: BUDI BAWAL (KAROLI), DISTRICT: ALWAR, RAJASTHAN, PIN: 301701 INDIA

Specification: BS 5467:2016 Incorporating Corrigendum No.1 Electric cables - Thermosetting insulated, armoured cables of rated voltages of 600/1000V and 1900/3300V for fixed installations - Specification

Type of Cable: Tables 5, 6, 7 & 8 Two-core, three-core, four-core and five-core 600/1000V cables with copper conductors

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 10sqmm to 400sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. 25sqmm to 70sqmm nominal cross-sectional area of conductors inclusive. Five-core. Sheath - Type 9. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: PARAMOUNT P-1

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 14/05/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 09/08/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

