BASEC
BRITISH APPROVALS SERVICE FOR CABLES

Product Certification Schedule

Schedule No:	158/001/101
Licensee:	OMAN CABLES INDUSTRY (SAOG), P.O. BOX NO. 25, RUSAYL, POSTAL CODE - 124, SULTANATE OF OMAN
Factory:	OMAN CABLES INDUSTRY (SAOG), P.O. BOX NO. 25, RUSAYL, POSTAL CODE - 124, SULTANATE OF OMAN
Specification:	BS 5467:2016 Incorporating Corrigendum No. 1 Electric cables - Thermosetting insulated, armoured cables of rated voltages of 600/1000V and 1900/3300V for fixed installations - Specification
Type of Cable:	Table 7 - Four-core 600/1000V cables with copper conductors
Range of Approval:	1.5sqmm to 400sqmm nominal cross-sectional area of conductors inclusive. Four-core. Sheath - Type 9. Insulation - GP8.
Origin Thread:	Not applicable
Origin Mark:	OMAN CABLES

PERMISSIBLE MARKS

BASEC

YELLOW ACETATE THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 22/04/2021

Signed for and on behalf of the British Approvals Service for Cables

Date 19/02/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

UKAS PRODUCT CERTIFICATION 004