

Certificate of Product Approval

Licensee:

Oman Cables Industry (SAOG)

P.O. Box No. 25, Rusayl, 124, Sultanate of Oman

Factory:

P.O. Box No. 25, Rusayl, 124, Sultanate of Oman

Standard:

BS 7629-1:2015

Description:

Fire resistant screened cables

Details:

STANDARD 60 - Additionally tested to BS 6387 Categories C, W & Z

Materials:

Insulation EI 5, Sheath LTS 3

Brand Name:

N/A

Origin Mark:

OMAN CABLES or PRYSMIAN (O)

Permissible Approval Marks:

BASEC



BASEC name

BASEC roundel

Signed for and on behalf of the
British Approvals Service for Cables

Tony Lioveri

Date: 04/05/2022

Date of original issue: 04/05/2022

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 1150237, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 3 (21-01-2021)



Expiry date:
22/04/2024

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
2	N/A	Class 1	2	1.5	2.5

Signed for and on behalf of the
British Approvals Service for Cables

Tony Lioveri

Date: 04/05/2022

Date of original issue: 04/05/2022

Check BASEC website to verify validity.

Page 2 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 1150237, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 3 (21-10-2021)



Expiry date:
22/04/2024