

Certificate of Product Approval

Licensee:

Oman Cables Industry (SAOG) Plant 2

Road no 4C & 4D, P.O. Box No. 25, Rusayl, Rusayl, 124, Sultanate of Oman

Factory:

Plant 2: Road no 4C & 4D, P.O. Box No. 25, Rusayl,, , 124, Sultanate of Oman

Standard:

BS 8592:2016

Description:

Single core fire resistant cables

Details:

These cables conform to BS 8592, and by reference, conform to the appropriate requirements of BS EN 60228, BS EN 60332-1-2, BS EN 61034-2, BS EN 60754-1 and IEC 60331-3.

Additionally tested to BS 8434-2:2003+A2:2009 (tests conducted in steel conduit modified by LWI064), BS EN 50200:2015 PH120 & BS EN 50200:2015 Annex E (tests conducted in steel conduit modified by LWI064), BS 6387 CWZ (tests conducted in steel conduit modified by LWI064) & IEC 60331-21. These cables have a rated voltage of 450/750V

Materials:

Insulation EI 5, Sheath N/A

Brand Name:

N/A

Origin Mark:

OMAN CABLES or PRYSMIAN (O)

Permissible Approval Marks:

BASEC

BASEC name



BASEC roundel

Signed for and on behalf of BASEC Group Ltd

Date: 14/02/2025

Date of original issue: 26/06/2024

Check BASEC website to verify validity.

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 6 (11-11-2024) Page 1 of 2



Expiry date:
22/10/2027

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
2	N/A	Class 2	1	1.5	70

Signed for and on behalf of BASEC Group Ltd



Date: 14/02/2025

Date of original issue: 26/06/2024

Check BASEC website to verify validity.

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No.13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 6 (11-11-2024) Page 2 of 2



Expiry date:
22/10/2027