

Product Certification Schedule

Schedule No: 164/001/060

Licensee: PAMUKKALE KABLO SANAYI VE TICARET A.S., EGS BUSINESS PARK
BLOKLARI, HAVAALANI KAVSAGI, B-1 BLOK K/16 NO:463, 34149
YESILKOY - ISTANBUL, TURKEY

Factory: PAMUKKALE KABLO SANAYI VE TICARET A.S., HACIEYUPLU MAH.
MENDERES BULVARI NO:5, MERKEZEFENDI, DENIZLI, TURKEY

Specification: BS 6724:2016 Incorporating Corrigenda Nos. 1 and 2 Electric cables-
Thermosetting insulated, armoured cables of rated voltages of 600/1 000 V and
1 900/3 300 V for fixed installations, having low emission of smoke and
corrosive gases when affected by fire - Specification

Type of Cable: Table 5, 6, 7 and 8 Two-core, three-core, four-core and five-core 600/1 000 V
cables with copper conductors

Range of Approval: 1.5sqmm to 400sqmm nominal cross-sectional area of conductors inclusive.
Two-core to four-core inclusive.
1.5sqmm to 70 sqmm nominal cross-sectional area of conductors inclusive.
Five-core.
Sheath - LTS1. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: PK of PAMUKKALE KABLO

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 13/12/2018

Signed for and on behalf of the British Approvals Service for Cables

Date 18/09/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



0004