

## Product Certification Schedule

Schedule No: 172/001/021

Licensee: NATIONAL CABLES INDUSTRY, PLOT # 6, BETWEEN 7TH AND 8TH INTERCHANGE, AL SAJA'A INDUSTRIAL AREA, AL DHAID ROAD, SHARJAH, UNITED ARAB EMIRATES

Factory: NATIONAL CABLES INDUSTRY, PLOT # 6, BETWEEN 7TH AND 8TH INTERCHANGE, AL SAJA'A INDUSTRIAL AREA, AL DHAID ROAD, SHARJAH, UNITED ARAB EMIRATES

Specification: BS 6724:2016 Incorporating Corrigenda Nos. 1 and 2 Electric cables - Thermosetting insulated, armoured cables of rated voltages of 600/1000V and 1900/3300V for fixed installations, having low emission of smoke and corrosive gases when affected by fire - Specification

Type of Cable: Table 4 Single-core 600/1000V cables with copper conductor

Range of Approval: 50sqmm to 1000sqmm nominal cross-sectional area of conductors inclusive. Single-core. Sheath - LTS1. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: NATIONAL CABLES INDUSTRY

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 04/01/2022

Signed for and on behalf of the British Approvals Service for Cables

Date 05/12/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



0004