

Product Certification Schedule

Schedule No: 187/001/022
Licensee: LA TRIVENETA CAVI S.P.A., VIA ORNA 35, 36040 BRENDOLA (VI), VICENZA, ITALY
Factory: LA TRIVENETA CAVI S.P.A., VIA DE GASPERI 19, 36040 BRENDOLA (VI), VICENZA, ITALY
Specification: BS 6231:2006 Incorporating Corrigendum No.1 Electric cables - Single core PVC insulated flexible cables of rated voltage 600/1000 V for switchgear and controlgear wiring
Type of Cable: Table 2 - PVC insulated flexible cable - Type CK
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: 0.5sqmm to 240sqmm nominal cross-sectional area of conductors inclusive. Single-core. Insulation - T13.
Origin Thread: Not Applicable
Origin Mark: LA TRIVENETA CAVI 2 or 187/001

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 29/07/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 20/07/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004