

Product Certification Schedule

Schedule No: 188/001/023

Licensee: OZGUVEN KABLO SAN. TIC. LTD. STI., HACIEYUPLU MAH. 3163 SOK. NO:2, 20050, DENIZLI, TURKEY

Factory: OZGUVEN KABLO SAN. TIC. LTD. STI., HACIEYUPLU MAH. 3163 SOK. NO:2, 20050, DENIZLI, TURKEY

Specification: BS 6004:2012 Electric Cables - PVC insulated and PVC sheathed cables for voltages up to and including 300/500V, for electric power and lighting

Type of Cable: Table 4
PVC insulated, PVC sheathed cable with circuit protective conductor (CPC), 300/500 V, single core 6241Y, flat twin 6242Y and flat 3-core 6243Y

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1sqmm to 1.5sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 1 conductor. 1sqmm to 2.5sqmm nominal cross-sectional area of conductors inclusive. Flat twin to flat 3-core inclusive. Class 1 conductor. 4sqmm to 16sqmm nominal cross-sectional area of conductors inclusive. Flat twin to flat 3-core inclusive. Class 2 conductor. Sheath - Type 6. Insulation - T11

Origin Thread: Not applicable

Origin Mark: OZGUVEN KABLO or OK

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 22/06/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 14/06/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

