

Product Certification Schedule

Schedule No: 188/001/024

Licensee: OZGUVEN KABLO SAN. TIC. LTD. STI., HACIEYUPLU MAH. 3163 SOK. NO:2, 20050, DENIZLI, TURKEY

Factory: OZGUVEN KABLO SAN. TIC. LTD. STI., HACIEYUPLU MAH. 3163 SOK. NO:2, 20050, DENIZLI, TURKEY

Specification: BS EN 50525-3-41:2011 Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (Uo/U) - Part 3-41: Cables with special fire performance - Single core non-sheathed cables with halogen-free crosslinked insulation, and low emission of smoke

Type of Cable: Heat resistant cables (90°C)
Clause 4.1 - Cables for fixed wiring - H07Z-U and H07Z-R
Table B.1 - Cables with rigid conductor (450/750 V)

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.5sqmm to 10sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 1 conductor. 1.5sqmm to 500sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 2 conductor. Insulation - E15.

Origin Thread: Not applicable

Origin Mark: OZGUVEN KABLO or OK

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 22/06/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 14/06/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004