

## Certificate of Product Approval

Licensee:  
**Draka UK Ltd**

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory:  
Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Standard:  
BS 7629-1:2015

Description:  
Fire resistant screened cables

Details:  
ENHANCED 120. Additionally tested to BS 6387:2013 Category CWZ.

Materials:  
Insulation EI 5, Sheath LTS 3

Brand Name:  
FT120 SAFFIRE

Origin Mark:  
DRAKA UK (B)

### Permissible Approval Marks:

**BASEC**



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals  
Service for Cables

*Tony Lioveri*

Date: 17/11/2020

Date of original issue: 08/07/2017

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:  
**11/08/2023**



Certificate No:  
**189/001/076**  
Issue No: 4

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
2	N/A	Class 1	2	1.5	2.5

Signed for and on behalf of the British Approvals Service for Cables

*Tony Lioveri* Date: 17/11/2020

Date of original issue: 08/07/2017  
Check BASEC website to verify validity.



Expiry date:  
**11/08/2023**