

## Certificate of Product Approval

Licensee:

**Draka UK Ltd**

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory:

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Standard:

BS 8592:2016

Description:

Single core non-sheathed fire resistant cables with thermosetting insulation and having low emission of smoke and corrosive gases when affected by fire

Details:

These cables conform to BS 8592, and by reference, conform to the appropriate requirements of BS EN 60228, BS EN 60332-1-2, BS EN 61034-2, BS EN 60754-1 and IEC 60331-3. Additionally tested to BS 8434-2:2003+A2:2009 and BS EN 50200:2015 PH120 (tests conducted in steel conduit). These cables have a rated voltage of 450/750V

Materials:

Insulation EI 5, Sheath None

Brand Name:

FT Sifer 950i

Origin Mark:

DRAKA UK (B)

### Permissible Approval Marks:

**BASEC**



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals Service for Cables

*Tony Lioveri*

Date: 18/11/2020

Date of original issue: 04/11/2020

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:  
**11/08/2023**



Certificate No:  
**189/001/080**  
Issue No: 1

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
2	N/A	Class 2	1	1.5	70

Signed for and on behalf of the British Approvals Service for Cables

*Tony Lioveri*

Date: 18/11/2020

Date of original issue: 04/11/2020

Check BASEC website to verify validity.

Page 2 of 2



Expiry date:  
**11/08/2023**