



# Certificate No: **189/001/080**

Issue No: 2

## Certificate of Product Approval

Licensee:

### Draka UK Ltd

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory: Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Standard: BS 8592:2016

Description:
Single core fire resistant cables

#### Details:

These cables conform to BS 8592, and by reference, conform to the appropriate requirements of BS EN 60228, BS EN 60332-1-2, BS EN61034-2, BS EN 60754-1 and IEC 60331-3. Additionally tested to BS 8434-2:2003+A2:2009 and BS EN 50200:2015 PH120 (tests conducted in steel conduit). These cables have a rated voltage of 450/750V

Materials: Insulation El 5, Sheath None

Brand Name: FT Sifer 950i

Origin Mark: DRAKA UK (B)

**Permissible Approval Marks:** 





BASEC name

BASEC roundel

Signed for and on behalf of BASEC Group Ltd

Krean O'Krin Date: 06/07/2023

Date of original issue: 04/11/2020 Check BASEC website to verify validity. Page 1 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK Registered in England No. 13950143, Tel: +44 (0)1908 267300 Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)





Expiry date: 11/08/2026





# Certificate No: **189/001/080**

Issue No: 2

### Type(s) and Range(s) of Approval

Table /	Code	Conductor	Range of	Min Nominal	Max Nominal
Clause	Designation	Class	Cores	Size -sqmm	Size - sqmm
2	N/A	Class 2	1	1.5	70

Signed for and on behalf of BASEC Group Ltd

Krean O'Krin Date: 06/07/2023

Date of original issue: 04/11/2020 Check BASEC website to verify validity. Page 2 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK Registered in England No.13950143, Tel: +44 (0)1908 267300 Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)

