

Certificate of Product Approval

Licensee:
Draka UK Ltd

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory:
Harriet Street

Trecynon, Aberdare, CF44 0TD, Glamorgan, United Kingdom

Standard:
BS 5467:2016 Incorporating Corrigendum No. 1

Description:
Thermosetting insulated, armoured cables with rated voltage of
600/1000V PVC sheathing

Details:

Materials:
Insulation GP 8, Sheath Type 9

Brand Name:

Origin Mark:
DRAKA UK (A)

Permissible Approval Marks:

BASEC



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals
Service for Cables

Tony Lioveri

Date: 19/11/2020

Date of original issue: 06/10/2012

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
11/08/2023



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
5	6942X	Class 2	2	1.5	35
6	6943X	Class 2	3	1.5	35
7	6944X	Class 2	4	1.5	35
8	6945X	Class 2	5	1.5	16

Signed for and on behalf of the British Approvals Service for Cables

Tony Lioveri

Date: 19/11/2020

Date of original issue: 06/10/2012

Check BASEC website to verify validity.

Page 2 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
11/08/2023