

Certificate of Product Approval

Licensee:

Draka UK Ltd

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory:

Oak Road

Wrexham Industrial Estate, Wrexham, LL13 9PH, Clwyd, United Kingdom

Standard:

BS 6724:2016 Incorporating Corrigenda Nos. 1 and 2

Description:

Thermosetting insulated, armoured cables with rated voltages of 600/1000V with Low Smoke Halogen Free sheathing

Details:

N/A

Materials:

Insulation GP 8, Sheath LTS 1

Brand Name:

N/A

Origin Mark:

DRAKA UK (W)

Permissible Approval Marks:

BASEC



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals Service for Cables

Tony Lioveri

Date: 13/01/2021

Date of original issue: 06/10/2012

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
11/08/2023



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
4	6941B	Class 2	1	95	1000
5	6942B	Class 2	2	70	400
6	6943B	Class 2	3	70	400
7	6944B	Class 2	4	70	400

Signed for and on behalf of the British Approvals Service for Cables

Tony Lioveri

Date: 13/01/2021

Date of original issue: 06/10/2012

Check BASEC website to verify validity.

Page 2 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
11/08/2023