BASEC
BRITISH APPROVALS SERVICE FOR CABLES

Product Certification Schedule

Schedule No:	191/001/072
Licensee:	EBION KABLO SANAYI TICARET ANONIM SIRKETI, HACI EYUPLU MAH., 3128 SOK. NO: 7 UCLER, DENIZLI, TURKEY
Factory:	EBION KABLO SANAYI TICARET ANONIM SIRKETI, HACI EYUPLU MAH., 3128 SOK. NO: 7 UCLER, DENIZLI, TURKEY
Specification:	BS 6004:2012 Electric Cables - PVC insulated and PVC sheathed cables for voltages up to and including 300/500V, for electric power and lighting
Type of Cable:	Table 4 PVC insulated, PVC sheathed cable with circuit protective conductor (CPC), 300/500 V, single core 6241Y, flat twin 6242Y and flat 3-core 6243Y
Range of Approval:	1sqmm to 1.5sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 1 conductor. 1sqmm to 2.5sqmm nominal cross-sectional area of conductors inclusive. Flat twin to flat 3-core inclusive. Class 1 conductor. 4sqmm to 16sqmm nominal cross-sectional area of conductors inclusive. Flat twin to flat 3-core inclusive. Class 2 conductor. Sheath - Type 6. Insulation - TI1.
Origin Thread:	Not applicable
Origin Mark:	ebion kablo or EB or EUROCAB or EXCEL

PERMISSIBLE MARKS

BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 05/09/2021

Signed for and on behalf of the British Approvals Service for Cables

Date 24/09/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

UKAS PRODUCT CERTIFICATION 0004