

## Certificate of Product Approval

Licensee:

**IDH Cables Limited**

Millbanks, New Ross, County Wexford, Ireland

Factory:

Millbanks, New Ross, County Wexford, Ireland

Standard:

BS 7629-1:2015

Description:

Fire resistant screened cables

Details:

STANDARD 60. Additionally tested to BS 6387 categories C, W & Z.

Materials:

Insulation EI 2, Sheath LTS 3

Brand Name:

N/A

Origin Mark:

IDH CABLES KILFLAM STANDARD 2000

### Permissible Approval Marks:

**BASEC**



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals  
Service for Cables

*Tony Lioveri*

Date: 19/11/2020

Date of original issue: 15/01/2016

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:  
**19/02/2024**



Type(s) and Range(s) of Approval

| Table / Clause | Code Designation | Conductor Class | Range of Cores | Min Nominal Size -sqmm | Max Nominal Size - sqmm |
|----------------|------------------|-----------------|----------------|------------------------|-------------------------|
| 2              | N/A              | N/A             | 2              | 1                      | 4                       |
| 2              | N/A              | N/A             | 3              | 1.5                    | 4                       |
| 2              | N/A              | N/A             | 4              | 1.5                    | 4                       |

Signed for and on behalf of the British Approvals Service for Cables

*Tony Lioveri*

Date: 19/11/2020

Date of original issue: 15/01/2016

Check BASEC website to verify validity.

Page 2 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:  
**19/02/2024**