

Certificate of Product Approval

Licensee:

IDH Cables Limited

Millbanks, New Ross, County Wexford, Ireland

Factory:

Millbanks, New Ross, County Wexford, Ireland

Standard:

BS 7629-1:2015

Description:

Fire resistant screened cables

Details:

ENHANCED 120. Additionally tested to BS 6387 Categories C, W & Z.

Materials:

Insulation EI 2, Sheath LTS 3

Brand Name:

N/A

Origin Mark:

IDH CABLES KILFLAM ENHANCED 3000

Permissible Approval Marks:

BASEC



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals
Service for Cables

Tony Lioveri

Date: 19/11/2020

Date of original issue: 20/04/2016

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
19/02/2024



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
2			2	1.5	4
2			3	1.5	2.5
2			4	1.5	2.5

Signed for and on behalf of the British Approvals Service for Cables

Tony Lioveri

Date: 19/11/2020

Date of original issue: 20/04/2016

Check BASEC website to verify validity.

Page 2 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
19/02/2024